



Strojirenský zkušební ústav, s.p., Brno, Česká republika  
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

# TEST CERTIFICATE

Number **O-B-000925-24**

Customer Kolton Spółka komandytowa  
ul. Sosnowa 2  
34-480 Jabłonka  
POLAND

Product Outdoor Air/Water Heat Pumps – monobloc

Type designation / Trade mark **Airadapt 3-12**  
**Airadapt 4-16**  
**Airadapt 4-20**

Test methods ČSN EN 14511-2:2019, ČSN EN 14511-3:2019,  
ČSN EN 14511-4:2019, ČSN EN 12102-1:2023, EHPA Testing  
regulation – Testing of Air/Water Heat Pumps, version 2.4a

Basis of certificate Test reports:  
39-16823/T of 2023-06-21  
39-17801/H of 2024-06-18  
Technical documents of KOLTON SPÓŁKA KOMANDYTOWA

Temperature application **LOW TEMPERATURE,**  
(Reference water temperature 35 °C)  
**MEDIUM TEMPERATURE**  
(Reference water temperature 55 °C)

## Specification of conditions:

Compressor speed control	<b>Variable</b>	Heating water volume flow rate (indoor heat exchanger)	<b>Variable</b>
Outlet water temperature (indoor heat exchanger)	<b>Variable</b>	Source liquid volume flow rate (outdoor heat exch.)	-
Function	<b>Reversible</b>		



O-B-000925-24, page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika  
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

[www.szutest.cz](http://www.szutest.cz)





**Results:**

Model names		Kořton Airadapt 3-12	Kořton Airadapt 4-16	Kořton Airadapt 4-20
Temperature condition*		(Not Tested)	(Not tested)	(Tested)
<b>A7/W35</b>	Corrected heating capacity [kW]	6.460	9.192	9.406
	Effective power input [kW]	1.222	1.734	1.707
	Coefficient of performance [-]	5.286	5.301	5.511
	Control settings [-]	-	-	-
<b>A7/W55</b>	Corrected heating capacity [kW]	6.038	9.062	9.539
	Effective power input [kW]	1.895	2.705	2.668
	Coefficient of performance [-]	3.187	3.350	3.576
	Control settings [-]	-	-	-
Sound power level at condition A7/W55* (at 1100 rpm):				
<b>LWA</b> Outdoor unit	[dB(A)]	53.0 ± 1.5	54.0 ± 1.5	54.5 ± 1.5
Accuracy class	Outdoor unit		Engineering (2)	

(\*) Comment to abbreviated marking e.g. A7W35:

„A“ air, „7“ inlet temperature (dry-bulb temperature) in °C, „W“ water, „35“ outlet temperature in °C.

(Tested) This test sample was tested at the Testing Laboratory.

(Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-06-25

**Ing. Mario Jankola**

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojírenský zkušební ústav, s.p., Brno, Česká republika  
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

# TEST CERTIFICATE

Number **O-B-000926-24**

Customer Kołton Spółka komandytowa  
ul. Sosnowa 2  
34-480 Jabłonna  
POLAND

Product Outdoor Air/Water Heat Pumps – monobloc

Type designation / Trademark **Airadapt 3-12**  
**Airadapt 4-16**  
**Airadapt 4-20**

Test methods ČSN EN 14511-2:2019, ČSN EN 14511-3:2019,  
ČSN EN 14511-4:2019, ČSN EN 12102-1:2023, EHPA Testing  
regulation – Testing of Air/Water Heat Pumps, version 2.4a

Basis of certificate Test reports:  
39-16823/T of 2023-06-21  
39-17801/H of 2024-06-18  
Technical documents of KOŁTON SPÓŁKA KOMANDYTOWA

Temperature application **LOW TEMPERATURE**  
(Reference water temperature 35 °C)

Reference heating season **„A“ = average / „W“ = warmer / „C“ = colder**  
(Reference design conditions for heating  $T_{designh} = -10\text{ °C} / +2\text{ °C} / -22\text{ °C}$ )

## Specification of conditions:

Compressor speed control	<b>Variable</b>	Heating water volume flow rate (indoor heat exchanger)	<b>Variable</b>
Outlet water temperature (indoor heat exchanger)	<b>Variable</b>	Source liquid volume flow rate (outdoor heat exch.)	-
Function	<b>Reversible</b>		



O-B-000926-24, page 1 (2)

Strojírenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika  
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

[www.szutest.cz](http://www.szutest.cz)





**Results:**

**Low temperature application**

(Reference water temperature 35 °C)


Model names		Kolton Airadapt 3-12 (Not tested)	Kolton Airadapt 4-16 (Not tested)	Kolton Airadapt 4-20 (Tested)
Full load heating	$P_{\text{designh}}$ [kW]	A	8.98	10.08
		W	10.10	13.05
		C	9.49	11.65
Bivalent temperature	$T_{\text{bivalent}}$ [°C]	A	-10	-10
		W	2	2
		C	-15	-15
Seasonal coefficient of performance	SCOP [-]	A	4.58	4.64
		W	6.31	6.52
		C	4.26	4.26
Seasonal Space heating energy efficiency	$\eta_s$ [%]	A	180.2	182.6
		W	249.4	257.6
		C	167.3	167.4

(Tested) This test sample was tested at the Testing Laboratory.

(Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-06-25

  
**Ing. Mario Jankola**

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojirenský zkušební ústav, s.p., Brno, Česká republika  
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

# TEST CERTIFICATE

Number **O-B-000927-24**

Customer **Kořton Spółka komandytowa**  
ul. Sosnowa 2  
34-480 Jabłonka  
POLAND

Product **Outdoor Air/Water Heat Pumps – monobloc**

Type designation / Trademark **Airadapt 3-12**  
**Airadapt 4-16**  
**Airadapt 4-20**

Test methods **ČSN EN 14511-2:2019, ČSN EN 14511-3:2019,  
ČSN EN 14511-4:2019, ČSN EN 12102-1:2023, EHPA Testing  
regulation – Testing of Air/Water Heat Pumps, version 2.4a**

Basis of certificate **Test reports:  
39-16823/T of 2023-06-21  
39-17801/H of 2024-06-18  
Technical documents of KOŁTON SPÓŁKA KOMANDYTOWA**

Temperature application **MEDIUM TEMPERATURE**  
(Reference water temperature 55 °C)

Reference heating season **„A“ = average / „W“ = warmer / „C“ = colder**  
(Reference design conditions for heating  $T_{designh} = -10\text{ °C} / +2\text{ °C} / -22\text{ °C}$ )

**Specification of conditions:**

Compressor speed control	<b>Variable</b>	Heating water volume flow rate (indoor heat exchanger)	<b>Variable</b>
Outlet water temperature (indoor heat exchanger)	<b>Variable</b>	Source liquid volume flow rate (outdoor heat exch.)	-
Function	<b>Reversible</b>		





**Results:**

**Medium temperature application**

(Reference water temperature 55 °C)

Model names		Kolton Airadapt 3-12	Kolton Airadapt 4-16	Kolton Airadapt 4-20
		(Not tested)	(Not tested)	(Tested)
Full load heating	$P_{designh}$ [kW]	A	8.15	10.02
		W	9.89	12.46
		C	9.54	11.41
Bivalent temperature	$T_{bivalent}$ [°C]	A	-10	-10
		W	2	2
		C	-15	-15
Seasonal coefficient of performance	SCOP [-]	A	3.83	3.83
		W	4.67	4.56
		C	3.55	3.51
Seasonal Space heating energy efficiency	$\eta_s$ [%]	A	150.1	150.2
		W	184.0	179.2
		C	138.9	137.3

(Tested) This test sample was tested at the Testing Laboratory.

(Not tested) The technical data were declared by the Manufacturer according to the model range specifications and were not tested by the Testing Laboratory.

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-06-25

**Ing. Mario Jankola**

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojirenský zkušební ústav, s.p., Brno, Česká republika  
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

# TEST CERTIFICATE

Number **O-B-01287-24**

Customer **Kolton Spółka komandytowa**  
**ul. Sosnowa 2**  
**34-480 Jablonka**  
**POLAND**

Product **Outdoor Air/Water Heat pump - monobloc**

Type designation / Trade mark **AirAdapt 4-20**

Test methods **ČSN EN 14511-4:2023, ČSN EN 12102-1:2023**

Basis of certificate  
Test reports:  
**39-17801/T of 2024-07-26**  
**39-17801/H of 2024-06-18**  
**Technical documents of Kolton Spółka komandytowa**

Temperature application **MEDIUM TEMPERATURE**  
(Reference water temperature 55 °C)

## Sound power level at temperature condition A7W55\*:


Outdoor Air/Water Heat pump - monobloc	<b>AirAdapt 4-20</b> – outdoor unit –
Sound power level	LWA <b>54.5 ± 1.5</b> dB(A)
Accuracy class	Engineering (grade 2)

(\*) Comment to abbreviated marking: e.g. A7/W55

A (air), 7 (input air – dry bulb temperature in °C) / W (water), 55 (output heating (cooling) water temperature in °C).



**Temperature operating range:**



**Liquid flow rate in:**

outdoor heating exchanger

Minimum 1.000 m<sup>3</sup>/h

Maximum 3.200 m<sup>3</sup>/h

indoor heating exchanger

Minimum 1.000 m<sup>3</sup>/h

Maximum 3.200 m<sup>3</sup>/h

Complies with  
ČSN EN 14511-4:2023, articles:

4.2.1.2; 4.2.1.3

**Specification of conditions:**

Compressor speed control	<b>Variable</b>	Heating water volume flow rate (indoor heat exchanger)	<b>Variable</b>
Outlet water temperature (indoor heat exchanger)	<b>Variable</b>	Source liquid volume flow rate (outdoor heat exchanger)	-
Function	<b>Reversible</b>		

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-07-30

**Ing. Mario Jankola**

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojírenský zkušební ústav, s.p., Brno, Česká republika  
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

# TEST CERTIFICATE

Number **O-B-01398-24**

Customer **Kořton Spółka komandytowa**  
ul. Sosnowa 2  
34-480 Jablonka  
POLAND

Product **Outdoor Air/Water Heat Pumps – monobloc**

Type designation / Trade mark **Kořton Airadapt 4-20**

Test methods **ČSN EN 14511-3:2019, ČSN EN 14825:2020, ČSN EN 12102-1:2023, EHPA Testing regulation – Testing of Air/Water Heat Pumps, version 2.4a**

Basis of certificate  
Test reports:  
39-16823/T of 2023-06-21  
39-17801/H of 2024-06-18  
Technical documents of KOŘTON SPÓŁKA KOMANDYTOWA

Reference heating season **„A“ = average**  
(Reference design temperature  $T_{designh} = -10\text{ °C}$ )

## Results:

**LOW TEMPERATURE**  
(Reference water temperature 35 °C)

**MEDIUM TEMPERATURE**  
(Reference water temperature 55 °C)

<b>13.85</b>	<b><math>P_{designh}</math> [kW] ... Full load heating</b>				<b>12.30</b>
<b>4.66</b>	<b>SCOP [-] ... Seasonal coefficient of performance</b>				<b>3.93</b>
Outdoor temperature $T_j$ [°C]	Heating declared capacity $P_{dh}$ [kW]	Coefficient of performance at the declared capacity $COP_d$ [-]	Outdoor temperature $T_j$ [°C]	Heating declared capacity $P_{dh}$ [kW]	Coefficient of performance at the declared capacity $COP_d$ [-]
$T_j = -7$	12.248	2.713	$T_j = -7$	10.356	2.485
$T_j = +2$	7.278	4.539	$T_j = +2$	6.368	3.889
$T_j = +7$	4.813	6.423	$T_j = +7$	4.599	4.940
$T_j = +12$	5.568	7.906	$T_j = +12$	5.407	6.109
$T_j = TOL = -10$	12.399	2.702	$T_j = TOL = -10$	12.303	2.174
$T_j = T_{bivalent} = -7$	12.248	2.713	$T_j = T_{bivalent} = -10$	12.303	2.174



**LOW TEMPERATURE**

(Reference water temperature 35 °C)

**MEDIUM TEMPERATURE**

(Reference water temperature 55 °C)

**Power consumption in modes other than „active mode“:**

17.6	Off mode	P <sub>OFF</sub>	[W]	17.6
22.0	Thermostat off mode	P <sub>TO</sub>	[W]	21.7
17.6	Standby mode	P <sub>SB</sub>	[W]	17.6
0.0	Crankcase heater mode	P <sub>CK</sub>	[W]	0.0

**Annual electricity consumption for heating according to:**

6135	ČSN EN 14825:2020	Q <sub>HE</sub>	[kWh]	6471
------	-------------------	-----------------	-------	------

**Seasonal Space heating energy efficiency**

183.5	ČSN EN 14825:2020	η <sub>s</sub>	[%]	154.1
-------	-------------------	----------------	-----	-------

**Liquid flow rate in outdoor heating exchanger:**

-	Source liquid	Min/Max	[m <sup>3</sup> /h]	-
---	---------------	---------	---------------------	---

**Liquid flow rate in indoor heating exchanger:**

1.000/3.200	Heating water	Min/Max	[m <sup>3</sup> /h]	1.000/3.200
-------------	---------------	---------	---------------------	-------------

**Sound power level at condition A7W55\* (at 10 %):**

**Kolton Airadapt 4-20**  
- outdoor unit -

L <sub>WA</sub>	54.5 ± 1.5	dB(A)
-----------------	------------	-------

Accuracy class 2 (Engineering)

(\*) Comment to abbreviated marking:

„A“ air, „7“ inlet temperature (dry-bulb temperature) in °C, „W“ water, „55“ outlet temperature in °C.

**Specification of conditions:**

Compressor speed control	<b>Variable</b>	Heating water volume flow rate (indoor heat exchanger)	<b>Variable</b>
Outlet water temperature (indoor heat exchanger)	<b>Variable</b>	Source liquid volume flow rate (outdoor heat exchanger)	-
Function	<b>Reversible</b>		

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-09-12



**Ing. Mario Jankola**

Heating Equipment and Construction Products Manager

- END OF TEST CERTIFICATE -





Strojirenský zkušební ústav, s.p., Brno, Česká republika  
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

# TEST CERTIFICATE

Number **O-B-01399-24**

Customer **Kořton Spółka komandytowa**  
ul. Sosnowa 2  
34-480 Jabłonka  
POLAND

Product **Outdoor Air/Water Heat Pumps – monobloc**

Type designation / Trade mark **Kořton Airadapt 4-20**

Test methods **ČSN EN 14511-3:2019, ČSN EN 14825:2020, ČSN EN 12102-1:2023, EHPA Testing regulation – Testing of Air/Water Heat Pumps, version 2.4a**

Basis of certificate  
Test reports:  
39-16823/T of 2023-06-21  
39-17801/H of 2024-06-18  
Technical documents of KOŘTON SPÓŁKA KOMANDYTOWA

Reference heating season **„W“ = warmer**  
(Reference design temperature  $T_{designh} = +2\text{ °C}$ )

## Results:

**LOW TEMPERATURE**  
(Reference water temperature 35 °C)

**MEDIUM TEMPERATURE**  
(Reference water temperature 55 °C)

16.05		$P_{designh}$ [kW] ... Full load heating		16.01	
6.34 (a)		SCOP [-] ... Seasonal coefficient of performance		4.59 (a)	
Outdoor temperature $T_j$ [°C]	Heating declared capacity $P_{dh}$ [kW]	Coefficient of performance at the declared capacity $COP_d$ [-]	Outdoor temperature $T_j$ [°C]	Heating declared capacity $P_{dh}$ [kW]	Coefficient of performance at the declared capacity $COP_d$ [-]
$T_j = -7$	–	–	$T_j = -7$	–	–
$T_j = +2$	16.049	3.390	$T_j = +2$	16.009	2.622
$T_j = +7^{(a)}$	10.550	5.730	$T_j = +7^{(a)}$	10.420	3.960
$T_j = +12^{(a)}$	5.620	7.750	$T_j = +12^{(a)}$	5.540	5.780
$T_j = TOL = +2$	16.049	3.390	$T_j = TOL = +2$	16.009	2.622
$T_j = T_{bivalent} = +2$	16.049	3.390	$T_j = T_{bivalent} = +2$	16.009	2.622



**LOW TEMPERATURE**

(Reference water temperature 35 °C)

**MEDIUM TEMPERATURE**

(Reference water temperature 55 °C)

**Power consumption in modes other than „active mode“:**

17.6	Off mode	$P_{OFF}$	[W]	17.6
22.0	Thermostat off mode	$P_{TO}$	[W]	21.7
17.6	Standby mode	$P_{SB}$	[W]	17.6
0.0	Crankcase heater mode	$P_{CK}$	[W]	0.0

**Annual electricity consumption for heating according to:**

3380.0 <sup>(a)</sup>	ČSN EN 14825:2020	$Q_{HE}$	[kWh]	4655.0 <sup>(a)</sup>
-----------------------	-------------------	----------	-------	-----------------------

**Seasonal Space heating energy efficiency**

250.7 <sup>(a)</sup>	ČSN EN 14825:2020	$\eta_s$	[%]	180.8 <sup>(a)</sup>
----------------------	-------------------	----------	-----	----------------------

**Liquid flow rate in outdoor heating exchanger:**

–	Source liquid	Min/Max	[m <sup>3</sup> /h]	–
---	---------------	---------	---------------------	---

**Liquid flow rate in indoor heating exchanger:**

1.000/3.200	Heating water	Min/Max	[m <sup>3</sup> /h]	1.000/3.200
-------------	---------------	---------	---------------------	-------------

**Sound power level at condition A7W55\* (at 10 %):**

**Koflon Airadapt 4-20**  
– outdoor unit –

LWA	54.5 ± 1.5	dB(A)
-----	------------	-------

Accuracy class 2 (Engineering)

(\*) Comment to abbreviated marking:

„A“ air, „7“ inlet temperature (dry-bulb temperature) in °C, „W“ water, „55“ outlet temperature in °C.

<sup>(a)</sup> The technical data were declared by the manufacturer or calculated of data declared by the manufacturer and were not tested by the Testing Laboratory.

**Specification of conditions:**

Compressor speed control	<b>Variable</b>	Heating water volume flow rate (indoor heat exchanger)	<b>Variable</b>
Outlet water temperature (indoor heat exchanger)	<b>Variable</b>	Source liquid volume flow rate (outdoor heat exchanger)	–
Function	<b>Reversible</b>		

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-09-12


**Ing. Mario Jankola**

Heating Equipment and Construction Products Manager

– END OF TEST CERTIFICATE –





Strojirenský zkušební ústav, s.p., Brno, Česká republika  
Engineering Test Institute, Public Enterprise, Brno, Czech Republic

# TEST CERTIFICATE

Number **O-B-01400-24**

Customer **Kolton Spółka komandytowa**  
ul. Sosnowa 2  
34-480 Jablonka  
POLAND

Product **Outdoor Air/Water Heat Pumps – monobloc**

Type designation / Trade mark **Kolton Airadapt 4-20**

Test methods **ČSN EN 14511-3:2019, ČSN EN 14825:2020, ČSN EN 12102-1:2023, EHPA Testing regulation – Testing of Air/Water Heat Pumps, version 2.4a**

Basis of certificate **Test reports:  
39-16823/T of 2023-06-21  
39-17801/H of 2024-06-18  
Technical documents of KOLTON SPÓŁKA KOMANDYTOWA**

Reference heating season **„C“ = colder  
(Reference design temperature  $T_{designh} = -22\text{ °C}$ )**

## Results:

**LOW TEMPERATURE**  
(Reference water temperature 35 °C)

**MEDIUM TEMPERATURE**  
(Reference water temperature 55 °C)

<b>14.42</b>	<b><math>P_{designh}</math> [kW] ... Full load heating</b>				<b>14.20</b>
<b>4.30 (a)</b>	<b>SCOP [-] ... Seasonal coefficient of performance</b>				<b>3.60 (a)</b>
Outdoor temperature $T_j$ [°C]	Heating declared capacity $P_{dh}$ [kW]	Coefficient of performance at the declared capacity $COP_d$ [-]	Outdoor temperature $T_j$ [°C]	Heating declared capacity $P_{dh}$ [kW]	Coefficient of performance at the declared capacity $COP_d$ [-]
$T_j = -7^{(a)}$	8.850	4.020	$T_j = -7^{(a)}$	8.850	3.080
$T_j = +2^{(a)}$	5.350	4.780	$T_j = +2^{(a)}$	5.450	4.320
$T_j = +7$	4.827	6.530	$T_j = +7$	4.657	5.209
$T_j = +12^{(a)}$	5.590	7.820	$T_j = +12^{(a)}$	5.540	7.060
$T_j = TOL = -20^{(a)}$	10.020	2.510	$T_j = TOL = -20^{(a)}$	9.850	1.810
$T_j = T_{bivalent} = -15$	11.767	2.734	$T_j = T_{bivalent} = -15$	11.582	2.208
$T_j = -15$	11.767	2.734	$T_j = -15$	11.582	2.208

O-B-01400-24, page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika  
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

[www.szutest.cz](http://www.szutest.cz)

**LOW TEMPERATURE**

(Reference water temperature 35 °C)

**MEDIUM TEMPERATURE**

(Reference water temperature 55 °C)

**Power consumption in modes other than „active mode“:**

17.6	Off mode	P <sub>OFF</sub>	[W]	17.6
22.0	Thermostat off mode	P <sub>TO</sub>	[W]	21.7
17.6	Standby mode	P <sub>SB</sub>	[W]	17.6
0.0	Crankcase heater mode	P <sub>CK</sub>	[W]	0.0

**Annual electricity consumption for heating according to:**

8267.0 <sup>(a)</sup>	ČSN EN 14825:2020	Q <sub>HE</sub>	[kWh]	9734.0 <sup>(a)</sup>
-----------------------	-------------------	-----------------	-------	-----------------------

**Seasonal Space heating energy efficiency**

169.0 <sup>(a)</sup>	ČSN EN 14825:2020	η <sub>s</sub>	[%]	140.8 <sup>(a)</sup>
----------------------	-------------------	----------------	-----	----------------------

**Liquid flow rate in outdoor heating exchanger:**

–	Source liquid	Min/Max	[m <sup>3</sup> /h]	–
---	---------------	---------	---------------------	---

**Liquid flow rate in indoor heating exchanger:**

1.000/3.200	Heating water	Min/Max	[m <sup>3</sup> /h]	1.000/3.200
-------------	---------------	---------	---------------------	-------------

**Sound power level at condition A7W55\* (at 10 %):****Kolton Airadapt 4-20**  
– outdoor unit –

LWA      54.5 ± 1.5      dB(A)

Accuracy class 2 (Engineering)

(\*) Comment to abbreviated marking:


„A“ air, „7“ inlet temperature (dry-bulb temperature) in °C, „W“ water, „55“ outlet temperature in °C.

<sup>(a)</sup> The technical data were declared by the manufacturer or calculated of data declared by the manufacturer and were not tested by the Testing Laboratory.**Specification of conditions:**

Compressor speed control	<b>Variable</b>	Heating water volume flow rate (indoor heat exchanger)	<b>Variable</b>
Outlet water temperature (indoor heat exchanger)	<b>Variable</b>	Source liquid volume flow rate (outdoor heat exchanger)	-
Function	<b>Reversible</b>		

Engineering Test Institute, Public Enterprise, confirms by this Test Certificate that the testing of the product in question was performed with the results as stated above. Engineering Test Institute, Public Enterprise, is an accredited Testing Laboratory 1045.1.

Brno, 2024-09-12


**Ing. Mario Jankola**

Heating Equipment and Construction Products Manager

– END OF TEST CERTIFICATE –

