

VOC Content Test Certificate

Thursday November 1st, 2011

Manufacturer: Forbo Flooring Systems (23 Ormsby Place, Wetherill Park, NSW 2164)

Sample Description: Forbo Fix L885 Marmoleum Sheet & Tile Adhesive

Date Tested: November 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p>Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p>Forbo Fix L885 Marmoleum Sheet & Tile Adhesive</p>
<p>Rubber flooring adhesive</p> <p>60 grams per Litre as VOC content per material</p>	<p>31 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV111125