

Classification Report

Number	17-003332-PR01 (NW-A01-02-en-01)
Owner	PROFILINK Ltd. 55 Nestor Abadzhiev Str. 4023 Plovdiv Bulgaria
Product	Double sliding window
Designation	Shipping name: Profilink Sliding System
Details	Manufacturer PROFILINK Ltd., - Plovdiv; Material Unplasticised polyvinyl chloride (uPVC), with reinforcement; Type of opening Sliding; Opening direction Active leaf right side; Overall dimensions (W x H) 2200 mm x 2000 mm
Special features	Construction with inside visible water flow

Result

Operating forces according to EN 13115:2001-07



Class: 1

Air permeability according to EN 12207:2016-12



Class: 3

Resistance to wind load according to EN 12210:2016-03



Class: C2/B2

Watertightness according to EN 12208:1999-11



Class: 4A

ift Rosenheim

23.02.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Daniel Gromotka, B.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 17-003332-PR01 PB-
A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 728-526A4