



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 13 04 84463 001

Certificate Holder:	Admira Pte Ltd 45 Sungei Kadut Avenue Singapore 729668 SINGAPORE
Product:	Finishing Materials For Wall/Ceiling
Brand Name:	ADMIRA
Model(s):	High Pressure Laminate
Product Details:	High Pressure Laminate bonded onto 6mm calcium silicate board Bulk Density: 1261 kg/m ³ Tested on the high pressure laminate face (Rating: Class 0)
Standard(s):	BS 476-6/A1:2009 BS 476-7:1997
Country of Origin	Germany, India, Indonesia, Italy, Japan
Test Report(s):	See COC Appendix (1 pg)
Issued on:	2013-04-26
Valid until:	2016-04-23
	 Vice-President (Certification Department) TÜV SÜD PSB

Page 1 of 2

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg





PSB Singapore

PRODUCT LISTING SCHEME APPENDIX

TO CERTIFICATE OF CONFORMITY NUMBER: CLS2 13 04 84463 001

Date of Issue : 2013-04-26

Issued To : **Admira Pte Ltd**
45 Sungei Kadut Avenue
Singapore 729668
SINGAPORE

Test Report : TÜV SÜD PSB Test No. 7191044512-MEC12/1-MHA
7191044512-MEC12/2-YWA

Vice President (Certification Department)
TÜV SÜD PSB